



Approval of the Trademark Trevira CS®

Gabriel A/S
Hjulgagervej 55
9000 Aalborg
Denmark

Application No.:	220658.3
Date of issue:	07.02.2024
Valid until:	27.09.2027
Article name:	Step/Step Melange
End use:	Drapes Upholstery fabrics Wall coverings
Square weight (g/m²):	335
According to customer specification	
Composition of the raw materials:	Polyester 100%
Composition of the fabric:	Trevira CS 100%

The article Step/Step Melange has been tested under the Trevira trademark application no. 220658 col 60090 and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1. The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507. The article has been tested according to CAN/ULC-S 109-14 Standard for Flame Tests of Flame-Resistant Fabrics and Films and meets the requirements of the Small and Large-Flame Test, see attached test report no. 51872 of Diversified Testing Laboratories dd 15.09.2022. The article has been tested according to CAN/ ULC-S102-10 Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies , results see attached test report no. 3-48801-0-V / 3-48801-1-V1 of SGS North America dd 24.08.2022. This article can meet the requirements according to California TB 117-2013, section 1 - cover fabric. This article meets class P-a according to DIN 66084 in combination with suitable combustion modified foams. This article meets the requirements according to EN 1021-1 and -2:2014 in conjunction with polyurethan foams with a density of more than 30 kg/m³. Thus meets also the requirements according to British Standard BS 5852: ignition source 0 (cigarette), ignition source 1 (match) and ignition source 5 (crib 5) in conjunction with suitable combustion modified foams (at least 50 kg/m³). Thus meets also the requirements according to the Italian standard UNI 9175, class 1 IM in conjunction with suitable combustion modified foams. This article can meet the requirements according to ÖNORM A 3800-1 part 1, class B1, fume formation class Q 1 and droplet formation class TR1. Thus meets also the requirements according to ÖNORM B 3825 in conjunction with suitable combustion modified foams. This article can meet the requirements according to FAR/JAR/CS 25.853 App. F to part 25, part I, § (a), (1) (ii) (vertical test, ignition time 12 sec). This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH
(This document is valid without signature.)